

European Network of Transmission System Operators for Electricity

1	
2	
3	
4	EXPLANATORY DOCUMENT on the Proposal for
5	RCC task of regional sizing of reserve capacity
6	in accordance with article 37(5) of Regulation
7	(EU) 2019/943 of the European Parliament and
8	of the Council of 5 June 2019 on the internal
9	market for electricity
10	
11	



12

13 TABLE OF CONTENT

14 15 16	EXPLANATORY DOCUMENT on the Proposal for RCC task of regional sizing of reserve capacity in accordance w article 37(5) of Regulation (EU) 2019/943 of the European Parliament and of the Council of 5 June 2019 on t internal market for electricity	i th he 1
17	Table of Content	.2
18	Introduction	.3
19	Relevant legislation and background	.4
20	Short-term assessment of availability of sharing amounts	.6
21 22	Example for short-term assessment of availability of sharing amounts Data exchange with RCC	7 9
23	Determination of minimum reserve capacity on SOR level	1
24	Numerical example on determination of Minimum Reserve Capacity on the SOR Level	14
25	Timeline	L 9
26	FREQUENTLY ASKED QUESTIONS (FAQ)	22
27	Glossary of terms	22
28		



30

INTRODUCTION 31

32 This explanatory note describes the TSOs' approach for the ENTSO-E proposal for the Regional Coordination 33 Centres' (RCCs) task of according to Articles 37(1)(j) of the Regulation (EU) 2019/943 (hereinafter "Electricity 34 Regulation"). Therefore, it gives background to the ENTSO-E proposal for the RCC task 'regional sizing of

35 reserve capacity'.

36 For the tasks set out in Article 37(1) of the Electricity Regulation and not already covered by the relevant

37 Network Codes or Guidelines, ENTSO-E shall develop a proposal according to Article 37(5) of the Electricity 38 Regulation based on the procedure set out in Article 27 of the Electricity Regulation RCCs shall carry out those 39 tasks on the basis of the proposal following its approval by ACER.

40 ENTSO-E identified that the RCC task according to Article 37(1)(j) of the Electricity Regulation – regional sizing

41 of reserve capacity - is not yet fully covered by the relevant network codes or guidelines. Therefore, ENTSO-

42 E decided to draft an ENTSO-E proposal defining this task to establish a coordinated understanding of the general aspects of the task. For the avoidance of doubt, regional in this context means the cross-border

43

44 interaction of TSOs related to reserve capacity.

45 The facilitation by the RCC shall be in line with the existing and applicable European and National legal 46 framework. Therefore, the RCC tasks defined in the ENTSO-E proposal must not go beyond facilitating the 47 TSOs task 'dimensioning of reserve capacity' on regional level according to Article 6(7) of the Electricity Regulation. The allocation of such a facilitating task to the RCC shall focus on providing an added value to the 48 49 relevant TSOs' task. TSOs shall have the final decision as they are obliged by regulation and liable accordingly 50 to perform the dimensioning. Additionally, TSOs' legal obligations and local approaches, reflecting technical 51 needs of the system, to define reserve capacity requirements and translating them into reserve capacity needs

52 and finally into balancing capacity amounts shall be respected.

53 With regards to the TSOs' task of dimensioning of reserve capacity, it shall be facilitated at regional level 54 according to Article 6(7) of the Electricity Regulation. ENTSO-E understands the proposed RCC task 'regional 55 sizing of reserve capacity' as the facilitation of the dimensioning of reserve capacity according to Article 6(7) 56 of the Regulation (EU) 118 2019/943.

57

58 This explanatory note gives more detailed information on the processes described in the proposal to define 59 the RCCs' task of regional sizing of reserve capacity. Therefore, it depicts how the proposed short-term 60 assessment of availability of sharing amounts and the determination of the minimum reserve capacity on the 61 system operation region (SOR) level together meet the requirements of Point 7 of Annex I of the Regulation

62 (EU) 2019/943, as ACER has agreed during alignment in the drafting phase to the TSOs.



64 RELEVANT LEGISLATION AND BACKGROUND

Article 40 of the Directive (EU) 2019/944¹ as well as requirements of Commission Regulation (EU) 2017/1485 65 establishing a guideline on electricity transmission system operation (hereinafter "SO Regulation"²) establish 66 67 the responsibilities of TSOs for local reserve dimensioning on Load Frequency Control (LFC) block level. In 68 addition, Article 6(7) of the Regulation (EU) 2019/943 requires that the dimensioning of reserve capacity on 69 LFC block level shall be performed by the TSOs and shall be facilitated at a regional level. This facilitation to 70 be performed by an RCC as described in the proposal, shall provide added value to TSOs of the corresponding 71 system operation region with a focus on the consideration of reserve sharing on a regional level and ensuring 72 sufficient reserve capacity in the SOR. This task of an RCC facilitating the TSOs' task of dimensioning reserve 73 capacity on a regional level shall be separate from and fully respect the local reserve dimensioning process 74 performed and owned by TSOs forming a Load Frequency Control (LFC) block, to maintain sufficient reserves 75 in the region covering those LFC blocks and be based on the dimensioning results.

76 Article 32(1) of EB Regulation requires among others that all TSOs of an LFC block shall regularly and at least 77 once a year review and define the reserve capacity requirements for the LFC block or scheduling areas of the 78 LFC block pursuant to dimensioning rules as referred to in Articles 157 and 160 SO Regulation respecting the 79 requirements of Article 127 SO Regulation. The SO Regulation obliges TSOs to perform the dimensioning of 80 frequency restoration reserves (FRR) and, when implemented, RR on the level of LFC blocks. The proposed 81 determination of minimum reserve capacity on SOR level by the RCC will ensure sufficient reserve capacity 82 in the SOR and also indicate to TSOs that there might be a possibility to reduce the dimensioned reserve 83 capacity by entering into a sharing agreement following the provisions of SO Regulation. By providing this 84 information at least on a yearly basis, the RCC facilitates the TSOs' dimensioning process.

85 According to Article 152(1) SO Regulation the objective of dimensioning reserve capacity FRR with automatic 86 activation (aFRR), FRR with manual activation (mFRR) and replacement reserves (RR) according to Articles 157 87 and Article 160 SO Regulation is to determine the reserve capacity need on an load frequency control (LFC) 88 block level in order to comply with the frequency restoration control error (FRCE) target parameters and 89 dimensioning rules and thus ensuring operational security. The focus is on compliance with technical 90 requirements. Accordingly, each TSO shall operate its control area with sufficient upward and downward 91 active power reserves, which may include shared or exchanged reserves, to face imbalances between demand 92 and supply within its control area.

93 Article 157(2)(b) SO Regulation requires that the FRR dimensioning shall take into account the restrictions for 94 the sharing of reserves defined in Article 157(2)(j), Article 157(2)(k), Article 160(4) and Article 160(5) SO 95 Regulation due to possible violations of operational security and the FRR availability requirements when 96 applying the probabilistic dimensioning methodology. Additionally, all TSOs forming an LFC block shall take 97 into account any expected significant changes to the distribution of LFC block imbalances or take into account 98 other relevant influencing factors relative to the time period considered. Furthermore, Article 157(2)(g) SO 99 Regulation states that all TSOs of an LFC block shall determine the reserve capacity on FRR of an LFC block, 100 any possible geographical limitations for its distribution within the LFC block and any possible geographical 101 limitations for any exchange of reserves or sharing of reserves with other LFC blocks to comply with the 102 operational security limits. Further, all TSOs of an LFC block may reduce the reserve capacity on FRR of the 103 LFC block resulting from the FRR dimensioning process by concluding an FRR sharing agreement with other

¹ Directive (EU) 2019/944 of the European Parliament and of the Council of 5 June 2019 on common rules for the internal market for electricity and amending Directive 2012/27/EU, available at: <u>https://eur-lex.europa.eu/legal-content/EN/TXT/?uri=CELEX%3A32019L0944</u>.

² Commission Regulation (EU) 2017/1485 of 2 August 2017 establishing a guideline on electricity transmission system operation (hereinafter "SO Regulation"), available at: <u>https://eur-lex.europa.eu/legal-content/EN/TXT/?uri=uriserv:OJ.L_2017.220.01.0001.01.ENG&toc=OJ:L:2017:220:TOC</u>



104 LFC blocks according to Article 157(2)(j) and Article 157(2)(k) SO Regulation. Therefore, TSOs are required to 105 assess the operational security before any sharing or exchange of FRR.

Articles 160(4) and 160(5) SO Regulation allow that all TSOs of an LFC block implementing an RR process (RR
 TSOs) may reduce the reserve capacity on RR of the LFC block, resulting from the RR dimensioning process,
 by developing an RR sharing agreement for positive or negative reserve capacity on RR with other LFC blocks.
 TSOs are required to assess the operational security before any sharing or exchange of RR.

- 110 Articles 166, 168 and 170 of SO Regulation define general requirements for sharing FRR and RR within a 111 synchronous area. Following the provisions of this Article, the parties participating in a sharing agreement are 112 a control capability receiving TSO and a control capability providing TSO. Following this, a sharing agreement 113 is in principle a unilateral agreement. If two TSOs have concluded a bilateral sharing agreement (consisting of 114 two unilateral sharing agreements) providing for the mutual provision of reserves, at least two unilateral 115 sharing agreements are established. As the sharing of reserves reduces the overall amount of available 116 reserves in the SOR, the RCC task 'regional sizing of reserve capacity' ensures operational security in a scenario 117 where the impact of an event involving at least two LFC blocks requiring those LFC blocks to activate reserves 118 simultaneously, needs to be assessed beyond each individual LFC block to guarantee appropriate reserve 119 capacity and thus system operational security in the region. Articles 177 and 179 of SO Regulation provide 120 general requirements for sharing FRR and RR between synchronous areas. Limits have to be defined by TSOs
- 121 to this sharing of reserves to ensure operational security.

122

The RCC task of regional sizing of reserve capacity facilitates the TSOs' consideration of reserve sharing amounts when determining the reserve capacity of the LFC block within their dimensioning process. The result of the collaboration between TSOs and the RCC under regional sizing of reserve capacity represents a lower bound for the required reserve capacity of each type of reserves in the system operation region (SOR) and thus aims to ensure operational security. This amount of reserves is at least required to fulfil the minimum requirements set out in Articles 157(2) and Article 160 SO Regulation resulting in a solution guaranteeing

129 sufficient reserve capacity in a region.

130



SHORT-TERM ASSESSMENT OF AVAILABILITY OF SHARING AMOUNTS

The 'short-term assessment of availability of sharing amounts' by RCCs is understood by TSOs as a subtask of the RCCs' task 'regional sizing of reserve capacity' as a process which takes place after TSO's dimensioning in a day-ahead or intraday timeframe. Thereby, the 'short-term assessment of availability of sharing amounts' takes place in full respect of the existing methodologies and processes approved locally by National Regulatory Authorities (NRAs) and already implemented by TSOs on an LFC block level. The results of the regional sizing performed by RCCs may be used by TSOs for a short-term increase of their required reserve capacity on LFC block level.

141 The sharing of reserves allows TSOs to decrease the reserve capacity of the LFC block resulting from the 142 dimensioning process (performed separately by each of the TSOs) by concluding a sharing agreement between 143 themselves. In the event that simultaneously (correlated) activation of shared reserves is required or a system 144 situation not allowing for the provision of the initially forecasted volumes of shared reserves, there is a risk of 145 insufficient reserve capacity in the region. Where a reserve sharing agreement exist within the SOR, the RCC 146 shall facilitate the involved TSOs in determining the necessary reserve capacity of the LFC block by notifying 147 the involved TSOs where and when the risk of simultaneously (correlated) activation of reserves exists. If this 148 event poses a threat to the operational security of the SOR, the RCC task results in recommending a possible 149 reduction of the amount of shared reserves to the relevant TSOs. Thus, this RCC task contributes significantly 150 to ensuring system security in the SOR.

151 Due to the pure operational and technical focus of the dimensioning process based on SO Regulation, the 152 focus of the RCC task of 'regional sizing of reserve capacity' is not on reducing the tender quantities of reserve 153 capacity considered necessary per LFC Block, but on increasing system operational security by guaranteeing 154 appropriate reserve capacity on a regional level. In particular, the TSOs' consideration of restrictions defined 155 in the agreements for the sharing of reserves or exchange of reserves due to possible violations of operational 156 security, the FRR availability requirements and possible limitations for any sharing of reserves or exchange of 157 reserves with other LFC blocks to comply with the operational security limits (Article 157(2)(b) and (g) SO 158 Regulation) shall be facilitated on a regional level by the RCC.

159 If based on the short-term assessment performed by the RCCs, the availability of shared reserve capacity 160 cannot be guaranteed due to simultaneously expected demands for reserve capacity in the relevant LFC blocks 161 or insufficient cross zonal capacity available between the LFC blocks, the RCC shall notify the involved LFC 162 blocks accordingly. Thus, the RCC recommendation suggests to the relevant TSO to increase locally available 163 reserve capacity, up to a maximum of the reserve capacity resulting from the dimensioning process, as the 164 TSO can no longer reduce its dimensioned reserve capacity by the sharing amount without threatening the 165 system operational security. If the recommendation includes an adjustment of sharing, the concerns of 166 affected TSOs, according to applicable guidelines and agreements, shall also be taken into account.

167 If based on the short-term assessment performed by the RCCs, the availability of increased shared reserve 168 capacity can be guaranteed in the relevant LFC blocks and sufficient cross zonal capacity is available between 169 the LFC blocks, the RCC shall notify the involved LFC blocks accordingly. This notification from the RCC of 170 the possibility to increase the sharing amount shall not be considered as a recommendation. The LFC block 171 may increase the sharing amount subject to the limits and requirements in the sharing agreement.

By allocating the short-term assessment of availability of sharing amounts to the RCC, more confidence is given to TSOs that there would be no decrease in system operational security when concluding a sharing agreement between themselves. From an economic efficiency point of view, the proposed RCC task avoids high expenses for remedial actions to maintain operational security in case of insufficient balancing capacity

available. Thus, the RCC task 'regional sizing of reserve capacity' allows TSOs to ensure operational security



with regards to complying with their frequency quality defining/target parameters in a cost-effective mannerby regional cooperation and coordination.

179 Example for short-term assessment of availability of sharing amounts

180 In this process, shown in the diagram on the following page, each LFCB making use of reserve sharing (as

181 reserve receiving TSO) provides the RCC with its own load forecasts, wind forecasts, solar forecasts,

expected hydro running, locally dimensioned reserve capacity, agreed reserve sharing amounts, cross zonal
 capacities and uncertainties related to current generation and load forecasts.

Based on the calculated regional sized reserve capacity and the uncertainties, the RCC may provide a recommendation on adjusting the amount of shared reserves used to decrease the final required reserve capacity for each type of reserves on LFCB level.

187 If based on comparison of the information provided the RCC determines that the agreed sharing amount 188 cannot or can only partially be provided to the control capability receiving TSO in the relevant period, the RCC 189 shall issue an awareness notification to these TSOs. The awareness notification should be issued 6 hours 190 before gate closure and the control capability providing TSO and the relevant affected TSO(s) shall be 191 informed.

- 192 On receiving the awareness notification, the control capability receiving TSO can:
- Adapt its reserve capacity;
- Adapt the request of allocating CZC for sharing of reserves;
- Request a review of the RCC recommendation in the case of new input data is available; or
- Deviate from the RCC recommendation, submitting a justification for its decision to RCC and to the other TSOs of the SOR

From SO Regulation article 157(2)(j)(i), for CE and Nordic synchronous areas, the amount of FRR that a LFC block can share is limited to the difference, if positive, between the size of the positive dimensioning incident and the reserve capacity on FRR required to cover the positive LFC block imbalances during 99% of the time. Additionally, the reduction in positive reserve capacity cannot exceed 30% of the dimensioning incident.

202

203



RCC Short Term Assessment of Availability of Sharing Amounts



The following is a non-exhaustive list of parameters that RCC may consider for the short-term assessment of simultaneous risk of activation of reserves. TSOs have the responsibility to provide forecasts to RCCs, and TSOs can delegate this responsibility to RCCs.

- Weather Conditions:
- 210 o High wind infeed, strong wind conditions
- 211 o High sun infeed (risk of clouds)
- 212 o Storms (Wind, snow)
- 213 o Uncertainties of the RES forecasts.

RCCs evaluate the risk of simultaneous occurrence of reserve activation among LFC Blocks having a sharing agreement in place by comparing the time series of above listed and delivered parameters. More details about the process will be specified during the Implementation phase.

- 217 TSOs may provide additional information to be considered by RCCs. This may include:
- Special Grid conditions:
- 219 New systems, new processes, implemented in LFC Blocks having a Sharing Agreement
- Fuel shortages (But this is probably more related to Adequacy issues, but the idea proposed is that such shortage could arrive suddenly)
- Specific Weather Conditions
- 223 Fast changes/ramp rates in RES, by identifying triggers of such fast changes in RES infeed
- 224 o Other implications on demand or generation

225 Data exchange with RCC

In this paragraph are described some possible data exchange foreseen between TSOs and RCCs. During the

implementation phase, more detailed data exchange and processes for performing the short-term assessmentwill be needed.

Data sent to RCCs by TSOs	Data sent by RCC to TSOs
Forecasts to be collected at minimum at the LFC Block level	Recommendation on increase of LFC Block
TSOs to investigate internally what parameters could be collected and transmitted to RCCs:	balancing capacities due to short-term assessment
	Minimum balancing capacity needs



- Wind speed
- Light intensity
- Load-forecast and influence factors such as temperature
- RES infeed in MW, optionally with location of this infeed in the LFC Block
- Risk of Wind decrease, unexpected level of RES infeed (to confirm that this risk is already taken into account)
- Risk of RES forecasts uncertainties
- Timing of the risk between LFC Blocks having a sharing agreement
- Forecast for Wind/Sun curtailment
- Negative prices (link with shutdown of RES infeed)
- Uncertainty ratio of unplanned unavailability (whether conditions, negative prices,...)

229



DETERMINATION OF MINIMUM RESERVE CAPACITY ON SOR LEVEL

To set up the methodology for determining the minimum reserve capacity which must be available on SOR level, TSOs took into account the provision of SO Regulation on the dimensioning of reserves. There are mainly two criteria underlying the dimensioning of reserves on LFC block level: the dimensioning incident or the probabilistic criterion (the reserve capacity must be able to cover the historical (positive and negative) imbalances at least 99% of the time).

SO Regulation allows TSOs of an LFC block to reduce the reserve capacity resulting from the dimensioning process by concluding a sharing of reserves agreement. Therefore, SO Regulation defines (for CE and Nordic SA) the possible sharing potential of an LFC block (for positive reserve capacity in general) as the minimum of { 30% of LFC block's dimensioning incident and the maximum of [zero and the (LFC block's dimensioning incident minus the amount of reserve capacity required to cover at least 99% of the historical imbalances of the LFC block) }

244 The LFC block imbalance corresponds to the ACE open loop following Article 3 (138) of SO Regulation).

The following gives three examples for the calculation of the sharing potential of a LFC block according to provisions of SO Regulation given the dimensioning incident in blue, the amount of reserve capacity required

provisions of SO Regulation given the dimensioning incident in blue, the amount of reserve capacity required
 to cover at least 99% of the historical imbalances of the LFC block in purple and the resulting sharing potential
 in green.



250 If LFC blocks conclude a sharing of reserves agreement in line with SO Regulation, this may lead to decreased 251 available reserves on LFC block level. Sharing of reserves is a useful option to comply with the locally 252 determined reserve capacity requirements to ensure system operational security in a cost effective manner. 253 On regional (SOR) level, sharing of reserves decreases the generally available reserves. Because of the 254 assumed anti correlation of LFC block imbalances, this in a first approach is reasonable. With increasing shares 255 of renewables and including other events with regional impact (e.g. system split), the assumption of anti-256 correlation can no longer be made steadily. Therefore, the RCC shall perform the proposed determination of 257 the minimum reserve capacity to be available on SOR level, to ensure operational security in the most cost 258 effective manner. If the summed up held reserve capacity (including the decrease by sharing of reserves) of 259 all LFC blocks within the SOR should fall below the determined minimum reserve capacity necessary on SOR 260 level, TSOs of the SOR would have to increase the available reserves to ensure operational security in the 261 region.

To determine the minimum reserves required on SOR level the criteria underlying the dimensioning on LFC block level were converted to SOR level. Therefore, the sizing incident was introduced on SOR level as a reflection of the dimensioning incident. In addition, an approach to calculate the amount of reserve capacity



required to cover at least 99% of the historical netted imbalances on SOR level was included in the proposal.
The maximum between those two values (dimensioning incident and historical imbalances coverage higher
than 99%).

Sizing incident' in this context means the maximum positive or negative power deviation occurring instantaneously between generation and demand in a system operation region, considered in the calculation of sharing potential. The sizing incident shall be the largest imbalance that may result from an instantaneous change of active power such as that of two power generating modules, two demand facilities, or two HVDC interconnectors or from a tripping of two AC lines, or it shall be the maximum instantaneous loss of active power consumption due to the tripping of one or two connection points. The sizing incident shall be determined separately for positive and negative direction.

In large systems such as CE, the amount of the generating capacity and demand leads to a larger probability of an additional loss of generation, consumption or in-feed before the system has recovered from a previous loss within the design window. Therefore, TSOs decided that an N-2 criterion shall be used to determine the sizing incident which is currently equivalent to 3000 MW - two biggest nuclear power units of 1500 MW each – for CE.

The minimum reserve capacity required on SOR level gives then two indications to the LFC Blocks within the SOR. First, it gives the minimum floor level to always be respected when multiple Sharing Agreement exist.

282 On the contrary it gives an indication to the TSOs willing to set a Sharing Agreement, about the available

amount of sharing that can still be implemented.

284 Netting of LFC Block imbalances within a SOR in accordance with Article 4(1c)

285 In order to sum up imbalances of LFC Blocks within a SOR, for a dedicated time serie, positive and negative

values of the LFC Blocks imbalances would be summed up, as illustrated in the figure below. When considering

all time series, then a chart with positive netted values can be drawn, and a chart with negative netted valuescan be drawn as well.



290 Historical Coverage (at least 99,99%)

289

For the following example a historical coverage rate of 99,99% was taken, as imbalance netting was included in the calculation of historic imbalances. Imbalance netting cannot be assumed to be available every time as a)



CZC must be available and b) there must be two opposed imbalances. Thus, a significantly higher historical coverage rate than 99% was applied. In the figure below you can see for positive netted imbalances, the process to compute the amount of needed Reserve capacity to cover at least 99,99% of the historical positive netted imbalances within the SOR. Similar chart for negative netted imbalances can be drawn. In the example below, in the considered SOR, the Needed Reserve Capacity to cover 99,99% of the time series with a Positive

298 Netted Imbalance equals to 6187 MW.





300

301 Numerical example on determination of Minimum Reserve Capacity on the SOR Level

302 The following scenario is based on a System Operation Region (SOR) consisting of four Load Frequency 303 Control Blocks (LFCB). Each LFCB has a positive and negative reserve requirement (Positive Reserves & 304 Negative Reserves). This requirement is the result of each individual LFCB's dimensioning process on FRR or 305 RR. In the scenario the LFCBs have concluded sharing of reserves agreements. One underlying assumption of the numerical example is that the demands for reserves of each LFCB are stochastically independent. Also 306 307 shown are the maximum agreed sharing amounts which are specified in a sharing agreement. A sharing 308 agreement is a bilateral contract where the obligation to provide reserves is unidirectional. If two TSOs have 309 concluded a sharing agreement on mutual sharing of reserves, at least two unidirectional obligations to provide reserves are established independent of each other. 310

As LFCB 2 and LFCB 4 do not have a common border, their sharing agreement will include LFCB 3 as an affected LFCB. The example assumes that the agreed sharing amounts are the same in the positive and negative directions, in reality this may not be the case.

SOR X

MW
nt 1000
ent -1000
ia) 800
eria) -800
nount 300



Maximum Agreed Sharing Amount	100
LFCB 4	MW
Positive Dimensioning Incident	500
Negative Dimensioning incident	-500
Positive Reserves (99% criteria)	450
Negative Reserves (99% criteria)	-500
Maximum Agreed Sharing Amount	100

314

315 To explain the arrangements on sharing of reserves in place:

316 The sharing of reserves agreement between LFCB 1 and LFCB 2 is a bilateral sharing of reserves 317 agreement with two unidirectional obligations. LFCB 1 has agreed to share up to a maximum of 100 318 MW of its reserve with LFCB 2 and LFCB 2 has agreed to share up to a maximum of 100 MW of its reserve with LFCB 1. This allows both LFCBs to reduce their locally dimensioned reserves by up to a 319 320 maximum of 100 MW each, using this sharing agreement. The maximum agreed sharing amount 321 between LFCB 1 and LFCB 2 is thus 100 MW in each direction. This results in a possible overall 322 reduction of local dimensioned reserve capacity in the region of 200 MW resulting from this sharing 323 of reserves agreement.

- The sharing of reserves agreement between LFCB 1 and LFCB 3 is a bilateral contract with one unidirectional obligation. In this agreement, LFCB 3 has agreed to share up to a maximum of 300 MW of its reserve with LFCB 1, but LFCB 1 does not share any of its reserve with LFCB 3. Thus, LFCB 1 can reduce its locally dimensioned reserves by up to a maximum of 300 MW, using this sharing agreement.
- LFCB 1 does not have a sharing agreement with LFCB 4.
- The sharing of reserves agreement between LFCB 2 and LFCB 3 is a bilateral contract with two unidirectional obligations. LFCB 2 has agreed to share up to a maximum of 100 MW of its reserve with LFCB 3 and LFCB 3 has agreed to share up to a maximum of 100 MW of its reserve with LFCB 2. This allows both LFCBs to reduce their locally dimensioned reserves by up to a maximum of 100 MW each, using this sharing agreement. The maximum agreed sharing amount between LFCB 2 and LFCB 3 is thus 100 MW in each direction. This results in a possible overall reduction of local reserve 336
- 337 The sharing of reserves agreement between LFCB 2 and LFCB 4 is a bilateral contract with two 338 unidirectional obligations. LFCB 2 has agreed to share up to a maximum of 100 MW of its reserve 339 with LFCB 4 and LFCB 4 has agreed to share up to a maximum of 100 MW of its reserve with LFCB 340 2. As they do not have a common border, LFCB 3 will have to be included as an affected LFCB. This 341 allows both LFCBs to reduce their locally dimensioned reserves by up to a maximum of 100 MW each, 342 using this sharing agreement. The maximum agreed sharing amount between LFCB 2 and LFCB 4 is 343 thus 100 MW in each direction. This results in a possible overall reduction of local reserve capacity 344 needs in the region of 200 MW resulting from this sharing of reserves agreement.
- LFCB 3 does not have a sharing agreement with LFCB 4.

346 Determination of the Minimum Reserve Capacity on the SOR Level

In this example, shown in the diagram on the next page, the RCC determines the SOR Positive Sizing Incident taking into account the change of active power of the two largest power generating modules (3000MW) and



the Negative Sizing Incident taking into account the loss of power consumption due to the tripping of two
 HVDC interconnectors (-2000MW). In this example, LFCB 3 has two 1500MW generating modules.

Using the historical imbalance values of the LFCBs, the RCC sums up (netting) per time period the positive and negative imbalance of all four LFCBs. From the netted imbalance time series a chart with positive netted values and a chart with negative netted values can be produced. Using the netted positive imbalances and netted negative imbalances the required reserve capacity to cover the aggregated positive SOR imbalances for at least 99.99% of the time and the required reserve capacity to cover the aggregated negative SOR imbalances for at least 99.99% of the time can be calculated. In this example:

- 357 Reserve capacity to cover positive SOR imbalances (for at least 99.99% of time) = 2750MW
- 358 Reserve capacity to cover negative SOR imbalances (for at least 99.99% of time) = -3000MW
- 359

366

The Reserve capacity to cover positive SOR imbalances (for at least 99.99% of time), 2750MW, is compared
 to the Positive Sizing Incident, 3000MW. The maximum of these two values is the Minimum Amount of

362 Required Positive Reserve Capacity for the SOR, 3000MW.

The reserve capacity to cover negative SOR imbalances (for at least 99.99% of time), -3000MW, is compared to the Negative Sizing Incident of -2000MW. The minimum of these two values is the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW.

As stated previously in this document, the SO Regulation allows TSOs of an LFC block to reduce the reserve capacity resulting from the dimensioning process by concluding a sharing of reserves agreement. The SO Regulation defines (for CE and Nordic SA) the possible sharing potential of an LFC block (for positive reserve capacity in general) as:

- The minimum of {30% of LFC block's dimensioning incident and the maximum of [zero and the (LFC block's dimensioning incident minus the amount of reserve capacity required to cover at least 99% of the historical imbalances of the LFC block)] }.
- 374

entsoe

ENTSO-E Proposals on RCC Sizing & Procurement Explanatory Note





 LFCB 1 requires to cover at least 99% of its historical imbalances is 800MW. Entering these values in the above equation results in: Minimum of [300 and [maximum of (0 and (1300 – 800)]] Minimum of [300 and [300 and [300]] For LFCB 1 the Positive Reserves Sharing Potential is 390MW. In this example, LFCB 2 has a positive dimensioning incident of 1000MW and the amount of reserve capacity LFCB 2 requires to cover at least 99% of its historical imbalances is 800MW. Entering these values in the above equation results in: Minimum of [100.3 x 1000] and [maximum of (0 and (1000 – 800)]] Minimum of [100.3 x 1000] and [maximum of 0 and (1000 – 800)]] Minimum of [300 and [maximum of (0 and 200]] For LFCB 2 the Positive Reserves Sharing Potential is 200MW. ErCB 3 requires to cover at least 99% of its historical imbalances is 1500MW. Entering these values in the above equation results in: Minimum of [300 and [maximum of (0 and (1500 – 1500)]] Minimum of [300 and [maximum of (0 and (1500 – 1500)]] Minimum of [300 and [maximum of (0 and (1500 – 1500)]] Minimum of [300 and [maximum of (0 and (1500 – 1500)]] Minimum of [300 and [300 and [300] For LFCB 3 the Positive Reserves Sharing Potential is 0MW. LFCB 4 requires to cover at least 99% of its historical imbalances is 450MW. Entering these values in the above equation results in: Minimum of [10.3 x 500] and [maximum of (0 and (500 – 450)]] Minimum of [10.3 x 500] and [maximum of (0 and (500 – 450)]] Minimum of [10.3 x 500] and [maximum of (0 and (500 – 450)]] Minimum of [10.3 x 500] and [maximum of (0 and (500 – 450)]] Minimum of [10.3 x 500] and [maximum of to and 50]] Minimum of [10.3 x 500] and [maximum of to and (500 – 450)]] Minimum of 150 and 10 Minimum of 150 and 50] Minimum of 150 and 10 Minimum of 150 and 50] Minimum of	377	In this example, LFCB 1 has a positive dimensioning incident of 1300MW and the amount of reserve capacity
above equation results in: Minimum of [100.3 x 1300] and [maximum of (0 and 1300 – 800)]] Minimum of [390 and [maximum of (0 and 500)] Minimum of [390 and 500] For LFCB 1 the Positive Reserves Sharing Potential is 390MW. In this example, LFCB 2 has a positive dimensioning incident of 1000MW and the amount of reserve capacity LFCB 2 requires to cover at least 99% of its historical imbalances is 800MW. Entering these values in the above equation results in: Minimum of [300 and [maximum of (0 and (1000 – 800)]] Minimum of 300 and [maximum of (0 and 1000 – 800)]] Minimum of [300 and 200] For LFCB 2 the Positive Reserves Sharing Potential is 200MW. Babove equation results in: Minimum of [300 and [maximum of (0 and (1500 – 1500)]] Minimum of [300 and [maximum of (0 and (1500 – 1500)]] Minimum of [300 and [maximum of (0 and (1500 – 1500)]] Minimum of [300 and [maximum of (0 and (1500 – 1500)]] Minimum of [300 and [maximum of (0 and (1500 – 1500)]] Minimum of [300 and [maximum of (0 and (1500 – 1500)]] Minimum of [300 and [maximum of (0 and (1500 – 1500)]] Minimum of [300 and [maximum of (0 and (1500 – 1500)]] Minimum of [300 and [maximum of (0 and (1500 – 1500)]] Minimum of [300 and [maximum of (0 and 500] For LFCB 4 has	378	LFCB 1 requires to cover at least 99% of its historical imbalances is 800MW. Entering these values in the
 Minimum of [[0.3 x 1300] and [maximum of (0 and [1300 – 800)]] Minimum of [390 and [500] For LFCB 1 the Positive Reserves Sharing Potential is 390MW. In this example, LFCB 2 has a positive dimensioning incident of 1000MW and the amount of reserve capacity LFCB 2 requires to cover at least 99% of its historical imbalances is 800MW. Entering these values in the above equation results in: Minimum of [(0.3 x 1000)] and [maximum of (0 and (1000 - 800))]] Minimum of [(0.3 x 1000)] and [maximum of (0 and (1000 - 800))]] Minimum of [0.3 x 1000] and [maximum of (0 and (1000 - 800))]] Minimum of [300 and [maximum of (0 and 1000 - 800))]] Minimum of [300 and [maximum of (0 and 1000 - 800))]] Minimum of [300 and [maximum of (0 and (1000 - 1500)W. For LFCB 2 the Positive Reserves Sharing Potential is 200MW. In this example, LFCB 3 has a positive dimensioning incident of 1500MW and the amount of reserve capacity LFCB 3 requires to cover at least 99% of its historical imbalances is 1500MW. Entering these values in the above equation results in: Minimum of [300 and [maximum of (0 and (1500 - 1500)]] Minimum of [300 and [maximum of (0 and (500 - 4500)]] Minimum of [300 and 300] For LFCB 4 has a positive dimensioning incident of 500MW and the amount of reserve capacity LFCB 4 requires to cover at least 99% of its historical imbalances is 450MW. Entering these values in the above equation results in: Minimum of [150 and [maximum of (0 and (500 - 450)]] Minimum of [150 and 50] For LFCB 4 the Positive Reserves Sharing Potential is 50MW. Similar calculations are performed to calculate the Negative Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserve Sharing Potential	379	above equation results in:
Minimum of (390 and [maximum of (0 and 500)] Minimum of (390 and 500) Bit Minimum of (390 and 500) Bit Minimum of (390 and 500) Bit Minimum of (10 and 1000) Bit Minimum of (10 and 1000) Bit Minimum of (10 and (maximum of (0 and (1000 - 800))]] Minimum of (10 and (maximum of (0 and (1000 - 800))]] Minimum of (300 and [maximum of (0 and (200)]] Minimum of (300 and (maximum of (0 and 200)]] Minimum of (300 and and (maximum of (0 and 1000 - 800))]] Minimum of (300 and 200) For LFCB 2 the Positive Reserves Sharing Potential is 200MW. Bit Minimum of (10 and 200) Minimum of (300 and 10) Minimum of (300 and (maximum of 0 and (1500 - 1500))] Minimum of (300 and 10) Minimum of (10 as 1 500) Minimum of (10 as	380	Minimum of {[(0.3 x 1300)] and [maximum of (0 and (1300 – 800))]}
382 Minimum of (390 and 500) 383 For LFCB 1 the Positive Reserves Sharing Potential is 390MW. 384 In this example, LFCB 2 has a positive dimensioning incident of 1000MW and the amount of reserve capacity 385 In this example, LFCB 2 has a positive dimensioning incident of 1000MW and the amount of reserve capacity 386 Minimum of (10.3 x 1000) and [maximum of (0 and (1000 - 800)]] 387 Minimum of (10.3 x 1000) and [maximum of (0 and (1000 - 800)]] 388 For LFCB 2 the Positive Reserves Sharing Potential is 200MW. 389 In this example, LFCB 3 has a positive dimensioning incident of 1500MW and the amount of reserve capacity 380 LFCB 3 requires to cover at least 99% of its historical imbalances is 1500MW. Entering these values in the 380 above equation results in: 381 Minimum of [100 and [maximum of (0 and (1500 - 1500)]]] 383 Minimum of [300 and [maximum of (0 and (500 - 450)]] 384 Horis example, LFCB 4 has a positive dimensioning incident of 500MW and the amount of reserve capacity 385 LFCB 4 requires to cover at least 99% of its historical imbalances is 450MW. Entering these values in the 386 above equation results in: 387 Minimum of [100 and [maximum of (0 and (500 - 450)]] 388 Minimum of [150 and [maxi	381	Minimum of {390 and [maximum of (0 and 500)]}
383 For LFCB 1 the Positive Reserves Sharing Potential is 390MW. 384 In this example, LFCB 2 has a positive dimensioning incident of 1000MW and the amount of reserve capacity 385 In this example, LFCB 2 has a positive dimensioning incident of 1000MW and the amount of reserve capacity 386 Minimum of [(03 0 and [maximum of (0 and (1000 - 800)]]) 387 Minimum of [300 and [maximum of (0 and (200]] 388 Minimum of [300 and [maximum of (0 and (1500 - 1500MW and the amount of reserve capacity 389 In this example, LFCB 3 has a positive dimensioning incident of 1500MW and the amount of reserve capacity 381 In this example, LFCB 3 has a positive dimensioning incident of 1500MW and the amount of reserve capacity 382 For LFCB 3 the Positive Reserves Sharing Potential is 0MW. 383 Minimum of [300 and [maximum of (0 and (1500 - 1500)]] 384 Minimum of [300 and [maximum of (0 and (500 - 450)]] 385 Minimum of [103 a x 500] and [maximum of (0 and (500 - 450)]] 386 Minimum of [103 a x 500] and [maximum of (0 and (500 - 450)]] 387 Minimum of [103 a x 500] and [maximum of (0 and 500] 388 For LFCB 4 the Positive Reserves Sharing Potential is 50MW. 389 For LFCB 4 the Positive Reserves Sharing Potential is 50MW. 380 Minimum	382	Minimum of {390 and 500}
 In this example, LFCB 2 has a positive dimensioning incident of 1000MW and the amount of reserve capacity LFCB 2 requires to cover at least 99% of its historical imbalances is 800MW. Entering these values in the above equation results in: Minimum of [10.3 x 1000] and [maximum of (0 and (2000 – 800)]] Minimum of [300 and 200] For LFCB 2 the Positive Reserves Sharing Potential is 200MW. In this example, LFCB 3 has a positive dimensioning incident of 1500MW and the amount of reserve capacity LFCB 3 requires to cover at least 99% of its historical imbalances is 1500MW. Entering these values in the above equation results in: Minimum of [300 and [0 and (10 and (10 and (1500 – 1500)]]] Minimum of [300 and [0 and [maximum of (0 and (1500 – 1500)]]] Minimum of [300 and [0 and [maximum of (0 and (1500 – 1500)]]] Minimum of [300 and [maximum of (0 and (150 – 1500)]]] Minimum of [300 and [maximum of (0 and (500 – 4500)]]] Minimum of [10.3 x 500]] and [maximum of (0 and (500 – 4500)]] Minimum of [10.3 x 500] and [maximum of (0 and (500 – 450)]]] Minimum of [10.3 x 500] and [maximum of (0 and 500] For LFCB 4 the Positive Reserves Sharing Potential is 50MW. Entering these values in the above equation results in: Minimum of [15.0 and 50] For LFCB 4 the Positive Reserves Sharing Potential is 50MW. Similar calculations are performed to calculate the Negative Reserves Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs reversignate further sharing or terves because the summed up positive Dimensioning Incidents per LFCB including the Sork, 3000MW, to the summed up Posit	383	For LFCB 1 the Positive Reserves Sharing Potential is 390MW.
 In this example, LFCB 2 has a positive dimensioning incident of 1000MW and the amount of reserve capacity LFCB 2 requires to cover at least 99% of its historical imbalances is 800MW. Entering these values in the above equation results in: Minimum of [100 and [maximum of (0 and (200)] Minimum of [300 and [maximum of (0 and 200)] For LFCB 2 the Positive Reserves Sharing Potential is 200MW. In this example, LFCB 3 has a positive dimensioning incident of 1500MW and the amount of reserve capacity LFCE 3 requires to cover at least 99% of its historical imbalances is 1500MW. Entering these values in the above equation results in: Minimum of (10.3 x 1500)] and [maximum of (0 and (1500 – 1500)]] Minimum of (10.3 x 1500)] and [maximum of (0 and (1500 – 1500)]] Minimum of (10.3 x 1500)] and [maximum of (0 and (1500 – 1500)]] Minimum of (10.3 x 1500)] and [maximum of (0 and (1500 – 1500)]] Minimum of (10.3 x 500)] and [maximum of (0 and (1500 – 1500)]] Minimum of [10.3 x 500)] and [maximum of (0 and (1500 – 450)]] Minimum of [10.3 x 500)] and [maximum of (0 and (500 – 450)]] Minimum of [10.3 x 500)] and [maximum of (0 and 500) For LFCB 4 the Positive Reserves Sharing Potential is 50MW. For LFCB 4 the Positive Reserves Sharing Potential is 50MW. Similar calculations are performed to calculate the Negative Reserves Sharing Potential of each of the LFCBs. Similar calculations are performed to calculate the Negative Reserves Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents pr LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs including positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can	384	
 LFCB 2 requires to cover at least 99% of its historical imbalances is 800MW. Entering these values in the above equation results in: Minimum of [300 and [maximum of (0 and 200)]] Minimum of [300 and 200] For LFCB 2 the Positive Reserves Sharing Potential is 200MW. In this example, LFCB 3 has a positive dimensioning incident of 1500MW and the amount of reserve capacity LFCB 3 requires to cover at least 99% of its historical imbalances is 1500MW. Entering these values in the above equation results in: Minimum of [300 and 200] For LFCB 3 the Positive Reserves Sharing Potential is 00MW. In this example, LFCB 3 has a positive dimensioning incident of 1500MW and the amount of reserve capacity LFCB 3 requires to cover at least 99% of its historical imbalances is 1500MW. Entering these values in the above equation results in: Minimum of [300 and 0] For LFCB 3 the Positive Reserves Sharing Potential is 0MW. LFCB 4 requires to cover at least 99% of its historical imbalances is 450MW. Entering these values in the above equation results in: Minimum of [150 and [maximum of (0 and (500 - 450)]] Minimum of [150 and [maximum of (0 and 50]] Minimum of [150 and finaximum of (0 and 50]] Minimum of [150 and finaximum of Required Positive Reserves Sharing Potential of each of the LFCBs. Similar calculations are performed to calculate the Negative Reserves Sharing Potential and each of the LFCBs. In this example, the RCC may recommend that the LFCBs including positive sharing potential is greater than 110% of the Minimum operational perspective it is on the one hand giving a higher security for the SOR, -3000MW, to the summed up Positive Dimensioning Incidents per LFCB including negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In thi	385	In this example, LFCB 2 has a positive dimensioning incident of 1000MW and the amount of reserve capacity
 above equation results in: Minimum of [[0.3 x 1000]] and [maximum of (0 and (1000 - 800))]] Minimum of [300 and [maximum of (0 and 200)] For LFCB 2 the Positive Reserves Sharing Potential is 200MW. In this example, LFCB 3 has a positive dimensioning incident of 1500MW and the amount of reserve capacity LFCE 3 requires to cover at least 99% of its historical imbalances is 1500MW. Entering these values in the above equation results in: Minimum of [300 and [maximum of (0 and 0]] Minimum of [300 and [maximum of (0 and 0]] Minimum of [300 and [maximum of (0 and 0]] Minimum of [300 and [maximum of (0 and 0]] Minimum of [300 and 0] For LFCB 3 the Positive Reserves Sharing Potential is 0MW. In this example, LFCB 4 has a positive dimensioning incident of 500MW and the amount of reserve capacity LFCE 4 requires to cover at least 99% of its historical imbalances is 450MW. Entering these values in the above equation results in: Minimum of [10.3 x 500)] and [maximum of (0 and 500 – 450)]] Minimum of [150 and [maximum of (0 and 50)] Minimum of [150 and [maximum of (0 and 500 – 450)]] Minimum of [150 and [maximum of Required Positive Reserves Sharing Potential of each of the LFCEs. Similar calculations are performed to calculate the Negative Reserves Sharing Potential of each of the LFCEs. By comparing the Minimum Amount of Required Positive Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs investigate further sharing of reserve sharing potential is greater than 110% of the Minimum 4mount of Required Positive Reserve Capacity for the SOR, -3000MW, to the summed up Positive Reserve Capacity for the SOR. The threshold was	386	LFCB 2 requires to cover at least 99% of its historical imbalances is 800MW. Entering these values in the
388 Minimum of [[[0.3 x 1000]] and [maximum of (0 and 200]]] 389 Minimum of [300 and 200] 391 For LFCB 2 the Positive Reserves Sharing Potential is 200MW. 392 In this example, LFCB 3 has a positive dimensioning incident of 1500MW and the amount of reserve capacity 393 In this example, LFCB 3 has a positive dimensioning incident of 1500MW. Entering these values in the above equation results in: 394 Minimum of [300 and [maximum of (0 and (1500 - 1500)]]] 395 Minimum of [300 and [maximum of (0 and 0]] 396 For LFCB 3 the Positive Reserves Sharing Potential is 0MW. 407 In this example, LFCB 4 has a positive dimensioning incident of 500MW and the amount of reserve capacity 416 Hork equations to cover at least 99% of its historical imbalances is 450MW. Entering these values in the above equation results in: 409 In this example, LFCB 4 has a positive dimensioning incident of 500MW and the amount of reserve capacity 417 LFCB 4 requires to cover at least 99% of its historical imbalances is 450MW. Entering these values in the above equation results in: 404 Minimum of [150 and [maximum of (0 and 500] 405 Minimum of [150 and [maximum of (0 and 500] 406 Minimum of LECB 4 the Positive Reserves Sharing Potential is 50MW. 407 For LFCB 4 the Positive Reserves Sha	387	above equation results in:
 Minimum of [300 and [maximum of (0 and 200)] Minimum of [300 and 200] For LFCB 2 the Positive Reserves Sharing Potential is 200MW. In this example, LFCB 3 has a positive dimensioning incident of 1500MW and the amount of reserve capacity LFCB 3 requires to cover at least 99% of its historical imbalances is 1500MW. Entering these values in the above equation results in: Minimum of [10.3 x 1500]] and [maximum of (0 and (1500 - 1500)]]} Minimum of [10.3 x 1500] and [maximum of (0 and 0.1500 - 1500)]]} Minimum of [300 and 0] For LFCB 3 the Positive Reserves Sharing Potential is 0MW. In this example, LFCB 4 has a positive dimensioning incident of 500MW and the amount of reserve capacity LFCB 4 requires to cover at least 99% of its historical imbalances is 450MW. Entering these values in the above equation results in: Minimum of [10.3 x 500)] and [maximum of (0 and (500 - 450)]] Minimum of [150 and 50] For LFCB 4 the Positive Reserves Sharing Potential is 50MW. Similar calculations are performed to calculate the Negative Reserves Sharing Potential of each of the LFCBs. By comparing the Minimum Amount of Required Positive Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs investigate further sharing of reserves because the summed up positive reserve of the LFCBs of the SOR including positive sharing potential is greater than 110% of the Minimum Amount of Required Positive Reserve Capacity for the SOR. The threshold was set to 110 % as from operational perspective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investig	388	Minimum of {[(0.3 x 1000)] and [maximum of (0 and (1000 – 800))]}
 Minimum of [300 and 200] For LFCB 2 the Positive Reserves Sharing Potential is 200MW. In this example, LFCB 3 has a positive dimensioning incident of 1500MW and the amount of reserve capacity LFCB 3 requires to cover at least 99% of its historical imbalances is 1500MW. Entering these values in the above equation results in: Minimum of [300 and maximum of (0 and (1500 – 1500)]] Minimum of [300 and maximum of (0 and 0)] Minimum of [300 and maximum of (0 and 0)] Minimum of [300 and maximum of (0 and 0)] Minimum of [300 and no) For LFCB 3 the Positive Reserves Sharing Potential is 0MW. In this example, LFCB 4 has a positive dimensioning incident of 500MW and the amount of reserve capacity LFCB 4 requires to cover at least 99% of its historical imbalances is 450MW. Entering these values in the above equation results in: Minimum of [150 and [maximum of (0 and (500 – 450)]] Minimum of [150 and 50] For LFCB 4 the Positive Reserves Sharing Potential is 50MW. Similar calculations are performed to calculate the Negative Reserves Sharing Potential of each of the LFCBs. By comparing the Minimum Amount of Required Positive Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs including positive sharing potential is greater than 110% of the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may necommend that the LFCBs reduce sharing potential sig grea	389	Minimum of {300 and [maximum of (0 and 200)]}
391 For LFCB 2 the Positive Reserves Sharing Potential is 200MW. 392 In this example, LFCB 3 has a positive dimensioning incident of 1500MW and the amount of reserve capacity 394 LFCB 3 requires to cover at least 99% of its historical imbalances is 1500MW. Entering these values in the above equation results in: 397 Minimum of [(10.3 x 1500)] and [maximum of (0 and (1500 - 1500))]] 398 Minimum of [300 and 0] 399 For LFCB 3 the Positive Reserves Sharing Potential is 0MW. 400 In this example, LFCB 4 has a positive dimensioning incident of 500MW and the amount of reserve capacity 401 In this example, LFCB 4 has a positive dimensioning incident of 500MW and the amount of reserve capacity 402 LFCB 4 requires to cover at least 99% of its historical imbalances is 450MW. Entering these values in the above equation results in: 403 Minimum of [103 and [maximum of (0 and (500 - 450)]] 404 Minimum of [150 and 50] 405 For LFCB 4 the Positive Reserves Sharing Potential is 50MW. 416 By comparing the Minimum Amount of Required Positive Reserves Sharing Potential of each of the LFCBs. 417 By comparing the Minimum Amount of Required Positive Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the	390	Minimum of {300 and 200}
 In this example, LFCB 3 has a positive dimensioning incident of 1500MW and the amount of reserve capacity LFCB 3 requires to cover at least 99% of its historical imbalances is 1500MW. Entering these values in the above equation results in: Minimum of [300 and [maximum of (0 and (1500 - 1500)]]) Minimum of [300 and [maximum of (0 and (1500 - 1500)]]) Minimum of [300 and [maximum of (0 and (1500 - 1500)]]) Minimum of [300 and [maximum of (0 and (1500 - 1500)]]) Minimum of [300 and 0] For LFCB 3 the Positive Reserves Sharing Potential is 0MW. In this example, LFCB 4 has a positive dimensioning incident of 500MW and the amount of reserve capacity LFCB 4 requires to cover at least 99% of its historical imbalances is 450MW. Entering these values in the above equation results in: Minimum of [150 and [maximum of (0 and (500 - 450)]]} Minimum of [150 and [maximum of (0 and 50]] Minimum of [150 and 50] For LFCB 4 the Positive Reserves Sharing Potential is 50MW. Similar calculations are performed to calculate the Negative Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserve Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs investigate further sharing of reserves because the summed up positive reserve of the SOR including positive Reserve Capacity for the SOR, 3000MW, to the summed up Regative Reserve Capacity for the SOR. The Minimum Amount of Required Negative Reserve Capacity for the SOR, 3000MW, to the Summed up Negative Reserve Capacity for the SOR. 3000MW, to the Summed up Negative Reserve Capacity for the SOR. 3000MW, to the Summed up Negative Dimensioning Incidents per LFCB including Negative Reserve Sharing Potential is greater than 110% of the Mi	391	For LFCB 2 the Positive Reserves Sharing Potential is 200MW.
10 In this example, LFCB 3 has a positive dimensioning incident of 1500MW and the amount of reserve capacity 17 LFCB 3 requires to cover at least 99% of its historical imbalances is 1500MW. Entering these values in the above equation results in: 17 Minimum of [[0.3 x 1500]] and [maximum of (0 and (1500 – 1500)]]] 17 Minimum of [300 and 0] 17 For LFCB 3 the Positive Reserves Sharing Potential is 0MW. 17 In this example, LFCB 4 has a positive dimensioning incident of 500MW and the amount of reserve capacity 17 In this example, LFCB 4 has a positive dimensioning incident of 500MW and the amount of reserve capacity 18 Honimum of [[0.3 x 500]] and [maximum of (0 and (500 – 450)]]] 19 Minimum of [150 and [maximum of (0 and 500 – 450)]]] 10 Minimum of [150 and [maximum of (0 and 500 – 450)]]] 10 Minimum of [150 and 50] 10 For LFCB 4 the Positive Reserves Sharing Potential is 50MW. 11 By comparing the Minimum Amount of Required Positive Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs investigate further sharing of reserves because the summed up positive reserve of the LFCBs of the SOR including positive sharing potential is greater than 110% of the Minimum Amount of	392	
 LFCB 3 requires to cover at least 99% of its historical imbalances is 1500MW. Entering these values in the above equation results in: Minimum of [300 and [maximum of (0 and (1500 - 1500)]]] Minimum of [300 and [maximum of (0 and 0]] Minimum of [300 and 0] For LFCB 3 the Positive Reserves Sharing Potential is 0MW. In this example, LFCB 4 has a positive dimensioning incident of 500MW and the amount of reserve capacity LFCB 4 requires to cover at least 99% of its historical imbalances is 450MW. Entering these values in the above equation results in: Minimum of [10.3 x 500] and [maximum of (0 and (500 - 450)]]] Minimum of [10.3 x 500] and [maximum of (0 and 500 - 450)]]] Minimum of [10.3 x 500] and [maximum of (0 and 500 - 450)]]] Minimum of [10.3 x 500] and [maximum of (0 and 500 - 450)]]] Minimum of [10.3 x 500] and [maximum of (0 and 500 - 450)]]] Minimum of [10.3 x 500] and [maximum of (0 and 500 - 450)]]] Minimum of [150 and 50] For LFCB 4 the Positive Reserves Sharing Potential is 50MW. Similar calculations are performed to calculate the Negative Reserves Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3640MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs investigate further sharing of reserves because the summed up positive reserve of the LFCBs of the SOR including positive sharing potential is greater than 110% of the Minimum Amount of Required Positive Reserve Capacity for the SOR, -3000MW, to the summed up Negative Reserves Capacity for the SOR. The threshold was set to 110 % as from operational perspective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to a	393	In this example, LECB 3 has a positive dimensioning incident of 1500MW and the amount of reserve capacity
above equation results in: Minimum of [(0.3 x 1500)] and [maximum of (0 and (1500 - 1500))]] Minimum of [300 and 0] For LFCB 3 the Positive Reserves Sharing Potential is 0MW. In this example, LFCB 4 has a positive dimensioning incident of 500MW and the amount of reserve capacity LFCB 4 requires to cover at least 99% of its historical imbalances is 450MW. Entering these values in the above equation results in: Minimum of [10:3 x 500]] and [maximum of (0 and (500 - 450))]] Minimum of [150 and [maximum of (0 and 50)] Minimum of [150 and [maximum of (0 and 50)] Minimum of [150 and [maximum of Required Positive Reserves Sharing Potential of each of the LFCBs. Similar calculations are performed to calculate the Negative Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs investigate further sharing of reserves because the summed up positive reserve of the LFCBs investigate further sharing of reserves because the summed up nositive reserve of the LFCBs investigate further sharing of reserves baring note than 110% of the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up negative it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investigations of small sharing amounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to	394	I FCB 3 requires to cover at least 99% of its historical imbalances is 1500MW. Entering these values in the
 Minimum of [[[0.3 x 1500]] and [maximum of (0 and (1500 - 1500)]]] Minimum of [300 and [maximum of (0 and 0)]] Minimum of [300 and [maximum of (0 and 0)]] For LFCB 3 the Positive Reserves Sharing Potential is 0MW. In this example, LFCB 4 has a positive dimensioning incident of 500MW and the amount of reserve capacity LFCB 4 requires to cover at least 99% of its historical imbalances is 450MW. Entering these values in the above equation results in: Minimum of [[10.3 x 500]] and [maximum of (0 and (500 - 450)]]] Minimum of [150 and [maximum of (0 and 50)]] Minimum of [150 and 50] For LFCB 4 the Positive Reserves Sharing Potential is 50MW. Similar calculations are performed to calculate the Negative Reserves Sharing Potential of each of the LFCBs. Similar calculations are performed to calculate the Negative Reserves Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs including positive sharing potential is greater than 110% of the Minimum Amount of Required Positive Reserve Capacity for the SOR3000MW, to the summed up Positive Reserve Capacity for the SOR. The threshold was set to 110 % as from operational perspective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investigations of small sharing amounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sh	395	above equation results in:
 Minimum of [300 and [maximum of [0 and 0]] Minimum of [300 and [maximum of [0 and 0]] Minimum of [300 and 0] For LFCB 3 the Positive Reserves Sharing Potential is 0MW. In this example, LFCB 4 has a positive dimensioning incident of 500MW and the amount of reserve capacity LFCB 4 requires to cover at least 99% of its historical imbalances is 450MW. Entering these values in the above equation results in: Minimum of [150 and [maximum of (0 and (500 – 450)]]] Minimum of [150 and [maximum of (0 and 50)] Minimum of [150 and [maximum of (0 and 50)]] Minimum of [150 and S0] For LFCB 4 the Positive Reserves Sharing Potential is 50MW. Similar calculations are performed to calculate the Negative Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. RCC may recommend that the LFCBs investigate further sharing potential is greater than 110% of the Minimum Amount of Required Positive Reserve Capacity for the SOR, -3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs investigate further sharing potential is greater than 110% of the Minimum Amount of Required Positive Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of	396	Minimum of $\{[(0, 3 \times 1500)] \text{ and } [maximum of (0 and (1500 - 1500))]\}$
 Minimum of (300 and 0) For LFCB 3 the Positive Reserves Sharing Potential is 0MW. In this example, LFCB 4 has a positive dimensioning incident of 500MW and the amount of reserve capacity LFCB 4 requires to cover at least 99% of its historical imbalances is 450MW. Entering these values in the above equation results in: Minimum of [[[0.3 x 500]] and [maximum of (0 and (500 - 450)]]] Minimum of [150 and [maximum of (0 and 500]] Minimum of [150 and [maximum of (0 and 500]] Minimum of [150 and [maximum of (0 and 50)]] Minimum of [150 and 50] For LFCB 4 the Positive Reserves Sharing Potential is 50MW. Similar calculations are performed to calculate the Negative Reserves Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs investigate further sharing of reserves because the summed up positive Reserve Capacity for the SOR. The threshold was set to 110 % as from operational prespective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investigations of small sharing amounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative sharing potential is in absolute terms not greater th	397	Minimum of $\{300 \text{ and } [maximum of (0 and 0)]\}$
 For LFCB 3 the Positive Reserves Sharing Potential is OMW. In this example, LFCB 4 has a positive dimensioning incident of 500MW and the amount of reserve capacity LFCB 4 requires to cover at least 99% of its historical imbalances is 450MW. Entering these values in the above equation results in: Minimum of [[10.3 x 500]] and [maximum of (0 and (500 - 450)]]} Minimum of [150 and [maximum of (0 and 500 - 450)]] Minimum of [150 and 50] For LFCB 4 the Positive Reserves Sharing Potential is 50MW. Similar calculations are performed to calculate the Negative Reserves Sharing Potential of each of the LFCBs. By comparing the Minimum Amount of Required Positive Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs investigate further sharing of reserves because the summed up positive reserve of the LFCBs of the SOR including positive sharing potential is greater than 110% of the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may not recommend that the LFCBs required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including n	398	Minimum of {300 and 0}
 In this example, LFCB 4 has a positive dimensioning incident of 500MW and the amount of reserve capacity LFCB 4 requires to cover at least 99% of its historical imbalances is 450MW. Entering these values in the above equation results in: Minimum of [[(0.3 x 500)] and [maximum of (0 and (500 - 450)]] Minimum of [150 and [maximum of (0 and 50)]] Minimum of [150 and [maximum of (0 and 50)]] For LFCB 4 the Positive Reserves Sharing Potential is 50MW. Similar calculations are performed to calculate the Negative Reserves Sharing Potential of each of the LFCBs. By comparing the Minimum Amount of Required Positive Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs including positive sharing potential is greater than 110% of the Minimum Amount of Required Positive Reserve Capacity for the SOR, -3000MW, to the summed up Required Positive Reserve Capacity for the SOR. The threshold was set to 110 % as from operational perspective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investigations of small sharing amounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative sharing potential is in absolute terms not greater than 95% of the	399	For LECB 3 the Positive Reserves Sharing Potential is OMW
 In this example, LFCB 4 has a positive dimensioning incident of 500MW and the amount of reserve capacity LFCB 4 requires to cover at least 99% of its historical imbalances is 450MW. Entering these values in the above equation results in: Minimum of [[10.3 x 500]] and [maximum of (0 and (500 - 450)]]] Minimum of [[150 and [maximum of (0 and 50]] Minimum of [[150 and 50] For LFCB 4 the Positive Reserves Sharing Potential is 50MW. Similar calculations are performed to calculate the Negative Reserves Sharing Potential of each of the LFCBs. By comparing the Minimum Amount of Required Positive Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs investigate further sharing of reserve because the summed up positive Reserve Capacity for the SOR. The threshold was set to 110 % as from operational perspective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investigations of small sharing amounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including positive reserve Capacity for the SOR. The threshold was set to 5% as from operational perspective it is on the one hand giving a higher security level if reserves capacit	400	
 LFCB 4 requires to cover at least 99% of its historical imbalances is 450MW. Entering these values in the above equation results in: Minimum of [[[0.3 x 500]] and [maximum of (0 and (500 - 450)]]} Minimum of [150 and [maximum of (0 and 50)]} Minimum of [150 and [maximum of (0 and 50)]} Minimum of [150 and 50] For LFCB 4 the Positive Reserves Sharing Potential is 50MW. Similar calculations are performed to calculate the Negative Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs investigate further sharing of reserves because the summed up positive reserve of the LFCBs of the SOR including positive sharing potential is greater than 110% of the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including verify level to have more than necessary reserves of the LFCBs of the SOR including positive sharing potential is greater than 110% of the Minimum Amount of Required Positive Reserve Capacity for the SOR. The threshold was set to 110 % as from operational perspective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investigations of small sharing amounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology becau	401	In this example, LECB 4 has a positive dimensioning incident of 500MW and the amount of reserve capacity
 above equation results in: Minimum of [[(0.3 x 500)] and [maximum of (0 and (500 - 450))]] Minimum of [150 and [maximum of (0 and 50]]] Minimum of [150 and [maximum of (0 and 50]]] Minimum of [150 and 50] For LFCB 4 the Positive Reserves Sharing Potential is 50MW. Similar calculations are performed to calculate the Negative Reserves Sharing Potential of each of the LFCBs. By comparing the Minimum Amount of Required Positive Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs investigate further sharing of reserves because the summed up positive reserve of the LFCBs of the SOR including positive sharing potential is greater than 110% of the Minimum Amount of Required Positive Reserve Capacity for the SOR. The threshold was set to 110 % as from operational perspective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investigations of small sharing mounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative Reserve Capacity for the SOR. The threshold was set to 95% as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the	402	IFCB 4 requires to cover at least 99% of its historical imbalances is 450MW. Entering these values in the
 Minimum of {[(0.3 x 500)] and [maximum of (0 and (500 - 450))]} Minimum of {150 and [maximum of (0 and 50)]} Minimum of {150 and 50} For LFCB 4 the Positive Reserves Sharing Potential is 50MW. Similar calculations are performed to calculate the Negative Reserves Sharing Potential of each of the LFCBs. By comparing the Minimum Amount of Required Positive Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs investigate further sharing of reserves because the summed up positive reserve of the LFCBs of the SOR including positive sharing potential is greater than 110% of the Minimum Amount of Required Positive Reserve Capacity for the SOR. The threshold was set to 110 % as from operational perspective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investigations of small sharing amounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR induding negative Reserve Capacity for the SOR. The threshold was set to 95% as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required level but on the other hand the actions may need a lot of coordination and the efforts to	403	above equation results in:
 Minimum of [150 and [maximum of (0 and 50)]] Minimum of [150 and [maximum of (0 and 50)]] Minimum of [150 and 50] For LFCB 4 the Positive Reserves Sharing Potential is 50MW. Similar calculations are performed to calculate the Negative Reserves Sharing Potential of each of the LFCBs. By comparing the Minimum Amount of Required Positive Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs including positive sharing potential is greater than 110% of the Minimum Amount of Required Positive Reserve Sort the LFCBs of the SOR including positive sharing potential is greater than 110% of the Minimum Amount of Required Positive Reserve Capacity for the SOR. The threshold was set to 110 % as from operational perspective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investigations of small sharing amounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative Reserve Capacity for the SOR. The threshold was set to 95 % as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required Negative Reserve Capacity for the SOR. The threshold was set to 95 % as from operational perspective i	404	Minimum of $\{[(0,3 \times 500)] \text{ and } [maximum of (0 and (500 - 450))]\}$
 Minimum of [150 and 50] For LFCB 4 the Positive Reserves Sharing Potential is 50MW. Similar calculations are performed to calculate the Negative Reserves Sharing Potential of each of the LFCBs. By comparing the Minimum Amount of Required Positive Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs investigate further sharing of reserves because the summed up positive reserve of the LFCBs of the SOR including positive sharing potential is greater than 110% of the Minimum Amount of Required Positive Reserve Capacity for the SOR. The threshold was set to 110 % as from operational perspective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investigations of small sharing amounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recomment that the LFCBs reduce sharing, revise the provision of reserve of the LFCBs of the SOR including negative Reserve Capacity for the SOR. The threshold was set to 95 % as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required level but on the other hand the actions may need a lot of coordination and the efforts to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned according SO Regulation. 	405	Minimum of {150 and [maximum of (0 and 50)]}
 For LFCB 4 the Positive Reserves Sharing Potential is 50MW. Similar calculations are performed to calculate the Negative Reserves Sharing Potential of each of the LFCBs. By comparing the Minimum Amount of Required Positive Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs investigate further sharing of reserves because the summed up positive reserve of the LFCBs of the SOR including positive sharing potential is greater than 110% of the Minimum Amount of Required Positive Reserve Capacity for the SOR. The threshold was set to 110 % as from operational perspective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investigations of small sharing amounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative Reserve Capacity for the SOR. The threshold was set to 95 % as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required level but on the other hand the actions may need a lot of coordination and the efforts to do so should not start for a small gap of regional	406	Minimum of {150 and 50}
Similar calculations are performed to calculate the Negative Reserves Sharing Potential of each of the LFCBs. By comparing the Minimum Amount of Required Positive Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs investigate further sharing of reserves because the summed up positive reserve of the LFCBs of the SOR including positive sharing potential is greater than 110% of the Minimum Amount of Required Positive Reserve Capacity for the SOR. The threshold was set to 110 % as from operational perspective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investigations of small sharing amounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative sharing potential is in absolute terms not greater than 95% of the Minimum Amount of Required Negative Reserve Capacity for the SOR. The threshold was set to 95 % as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required level but on the other hand the actions may need a lot of coordination and the efforts to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned according SO Regulation.	407	For LECB 4 the Positive Reserves Sharing Potential is 50MW
Similar calculations are performed to calculate the Negative Reserves Sharing Potential of each of the LFCBs. By comparing the Minimum Amount of Required Positive Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs investigate further sharing of reserves because the summed up positive reserve of the LFCBs of the SOR including positive sharing potential is greater than 110% of the Minimum Amount of Required Positive Reserve Capacity for the SOR. The threshold was set to 110 % as from operational perspective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investigations of small sharing amounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative sharing potential is in absolute terms not greater than 95% of the Minimum Amount of Required Negative Reserve Capacity for the SOR. The threshold was set to 95 % as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required level but on the other hand the actions may need a lot of coordination and the efforts to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned according SO Regulation.	408	
By comparing the Minimum Amount of Required Positive Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs investigate further sharing of reserves because the summed up positive reserve of the LFCBs of the SOR including positive sharing potential is greater than 110% of the Minimum Amount of Required Positive Reserve Capacity for the SOR. The threshold was set to 110 % as from operational perspective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investigations of small sharing amounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative Reserve Capacity for the SOR. The threshold was set to 95 % as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required Negative Reserve Capacity for the SOR. The threshold was set to 95 % as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required level but on the other hand the actions may need a lot of coordination and the efforts to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned according SO Regulation.	409	Similar calculations are performed to calculate the Negative Reserves Sharing Potential of each of the LECBs
By comparing the Minimum Amount of Required Positive Reserve Capacity for the SOR, 3000MW, to the summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs investigate further sharing of reserves because the summed up positive reserve of the LFCBs of the SOR including positive sharing potential is greater than 110% of the Minimum Amount of Required Positive Reserve Capacity for the SOR. The threshold was set to 110 % as from operational perspective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investigations of small sharing amounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative Reserve Capacity for the SOR. The threshold was set to 95 % as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required Negative Reserve Capacity for the SOR. The threshold was set to 95 % as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required level but on the other hand the actions may need a lot of coordination and the efforts to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned according SO Regulation.	410	ommul culculutons are performed to calculate the regulive reserves onarmy rotential of each of the Li obs.
summed up Positive Dimensioning Incidents per LFCB including the Positive Reserves Sharing Potential amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs investigate further sharing of reserves because the summed up positive reserve of the LFCBs of the SOR including positive sharing potential is greater than 110% of the Minimum Amount of Required Positive Reserve Capacity for the SOR. The threshold was set to 110 % as from operational perspective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investigations of small sharing amounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative Reserve Capacity for the SOR. The threshold was set to 95% as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required Negative Reserve Capacity for the SOR. The threshold was set to 95% as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required Negative Reserve capacity for the SOR. The threshold was set to 95% as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required Negative Reserve Capacity for the SOR. The threshold was set to 95% as from operational perspective it is on the one hand giving a higher se	411	By comparing the Minimum Amount of Required Positive Reserve Capacity for the SOR 3000MW to the
amounts, 3660MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example, the RCC may recommend that the LFCBs investigate further sharing of reserves because the summed up positive reserve of the LFCBs of the SOR including positive sharing potential is greater than 110% of the Minimum Amount of Required Positive Reserve Capacity for the SOR. The threshold was set to 110 % as from operational perspective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investigations of small sharing amounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative Reserve Capacity for the SOR. The threshold was set to 95% as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required level but on the other hand the actions may need a lot of coordination and the efforts to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned according SO Regulation.	412	summed up Positive Dimensioning Incidents per LECB including the Positive Reserves Sharing Potential
 RCC may recommend that the LFCBs investigate further sharing of reserves because the summed up positive reserve of the LFCBs of the SOR including positive sharing potential is greater than 110% of the Minimum Amount of Required Positive Reserve Capacity for the SOR. The threshold was set to 110 % as from operational perspective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investigations of small sharing amounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative Reserve Capacity for the SOR. The threshold was set to 95% as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required level but on the other hand the actions may need a lot of coordination and the efforts to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned according SO Regulation. 	413	amounts 3660MW with a tolerance the RCC can make a recommendation to the LECBs. In this example the
 reserve of the LFCBs of the SOR including positive sharing potential is greater than 110% of the Minimum Amount of Required Positive Reserve Capacity for the SOR. The threshold was set to 110 % as from operational perspective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investigations of small sharing amounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative Reserve Capacity for the SOR. The threshold was set to 95% as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required level but on the other hand the actions may need a lot of coordination and the efforts to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned 	414	RCC may recommend that the LECBs investigate further sharing of reserves because the summed up positive
Amount of Required Positive Reserve Capacity for the SOR. The threshold was set to 110 % as from operational perspective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investigations of small sharing amounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative sharing potential is in absolute terms not greater than 95% of the Minimum Amount of Required Negative Reserve Capacity for the SOR. The threshold was set to 95 % as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required level but on the other hand the actions may need a lot of coordination and the efforts to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned according SO Regulation.	415	reserve of the LECBs of the SOR including positive sharing potential is greater than 110% of the Minimum
operational perspective it is on the one hand giving a higher security level to have more than necessary reserves available and on the other hand to avoid too frequent investigations of small sharing amounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative Reserve Capacity for the SOR. The threshold was set to 95% as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required level but on the other hand the actions may need a lot of coordination and the efforts to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned 430 according SO Regulation.	416	Amount of Required Positive Reserve Capacity for the SOR. The threshold was set to 110 % as from
reserves available and on the other hand to avoid too frequent investigations of small sharing amounts. By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative sharing potential is in absolute terms not greater than 95% of the Minimum Amount of Required Negative Reserve Capacity for the SOR. The threshold was set to 95 % as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required level but on the other hand the actions may need a lot of coordination and the efforts to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned according SO Regulation.	417	operational perspective it is on the one hand giving a higher security level to have more than necessary
By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative sharing potential is in absolute terms not greater than 95% of the Minimum Amount of Required Negative Reserve Capacity for the SOR. The threshold was set to 95 % as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required level but on the other hand the actions may need a lot of coordination and the efforts to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned according SO Regulation.	418	reserves available and on the other hand to avoid too frequent investigations of small sharing amounts.
By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR, -3000MW, to the summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative sharing potential is in absolute terms not greater than 95% of the Minimum Amount of Required Negative Reserve Capacity for the SOR. The threshold was set to 95 % as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required level but on the other hand the actions may need a lot of coordination and the efforts to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned according SO Regulation.	419	reserves available and on the other hand to avoid too frequent investigations of small sharing amounts.
summed up Negative Dimensioning Incidents per LFCB including Negative Reserves Sharing Potential amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative sharing potential is in absolute terms not greater than 95% of the Minimum Amount of Required Negative Reserve Capacity for the SOR. The threshold was set to 95 % as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required level but on the other hand the actions may need a lot of coordination and the efforts to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned according SO Regulation.	420	By comparing the Minimum Amount of Required Negative Reserve Capacity for the SOR -3000MW to the
amounts, -2950MW, with a tolerance, the RCC can make a recommendation to the LFCBs. In this example the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative sharing potential is in absolute terms not greater than 95% of the Minimum Amount of Required Negative Reserve Capacity for the SOR. The threshold was set to 95 % as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required level but on the other hand the actions may need a lot of coordination and the efforts to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned according SO Regulation.	421	summed up Negative Dimensioning Incidents per LECB including Negative Reserves Sharing Potential
the RCC may not recommend that the LFCBs reduce sharing, revise the provision of reserve capacity, and/or propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative sharing potential is in absolute terms not greater than 95% of the Minimum Amount of Required Negative Reserve Capacity for the SOR. The threshold was set to 95 % as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required level but on the other hand the actions may need a lot of coordination and the efforts to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned according SO Regulation.	422	amounts -2950MW with a tolerance the RCC can make a recommendation to the LECBs. In this example
propose improvements to the regional sizing methodology because the summed up negative reserve of the LFCBs of the SOR including negative sharing potential is in absolute terms not greater than 95% of the Minimum Amount of Required Negative Reserve Capacity for the SOR. The threshold was set to 95 % as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required level but on the other hand the actions may need a lot of coordination and the efforts to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned according SO Regulation.	423	the RCC may not recommend that the LECBs reduce sharing revise the provision of reserve canacity and/or
LFCBs of the SOR including negative sharing potential is in absolute terms not greater than 95% of the Minimum Amount of Required Negative Reserve Capacity for the SOR. The threshold was set to 95% as from operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as possible to the required level but on the other hand the actions may need a lot of coordination and the efforts to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned according SO Regulation.	424	propose improvements to the regional sizing methodology because the summed up negative reserve of the
426 Minimum Amount of Required Negative sharing potential is in absolute terms not greater than 75% of the 427 operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as 428 possible to the required level but on the other hand the actions may need a lot of coordination and the efforts 429 to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned 430 according SO Regulation.	425	I FCBs of the SOR including negative sharing notential is in absolute terms not greater than 95% of the
427 operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as 428 possible to the required level but on the other hand the actions may need a lot of coordination and the efforts 429 to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned 430 according SO Regulation.	426	Minimum Amount of Required Negative Reserve Capacity for the SOR. The threshold was set to 95 % as from
428 possible to the required level but on the other hand the actions may need a lot of coordination and the efforts 429 to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned 430 according SO Regulation.	427	operational perspective it is on the one hand giving a higher security level if reserves are increased as soon as
429 to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned 430 according SO Regulation.	428	possible to the required level but on the other hand the actions may need a lot of coordination and the efforts
430 according SO Regulation.	429	to do so should not start for a small gap of regional sized reserve capacity and reserve capacity dimensioned
	430	according SO Regulation.



431

432 **TIMELINE**

In order to take into account, the fact that the RCCs have not been active in the field of balancing until today
and thus completely new tasks arise for them, an implementation period of at least 36 months seems
appropriate.

The proposed implementation timeline considers the fact that RCCs involvement in this "Regional sizing of reserve capacity" is a new task specified by the CEP. This process is historically performed by TSOs. Thus, the implementation period of 36 months is supported by the following points:

- Sizing of reserve capacity is a completely new task and processes that needs to be at the RCCs. So
 RCCs will learn and develop the service from a black paper.
- The proposal is referring to a regional sizing of reserve capacity, however, it is not mentioned if the technical implementation (and it is not its goal) should be done on regional level or on pan-European level. So, RCCs will clarify within different SORs to align on the specific regional technical solutions.
 Even if having a common European tool shared by all RCCs needs to take into account the regional specificities.
- After this alignment all together either at regional or pan-European level, the timing also takes into account the potential duration related to specifications, tendering for IT solution, development of the IT solution. This is followed by the validation of the technical solution, its implementation including testing and parallel run and of course the stabilisation phase.
- 450

		goal	start	end	time interval
1.	Regional alignment		1.1.2023	28.2.2024	423
1.1.	Clarificati on of tasks to be requested by TSOs	Determini ng the tasks on the regional sizing of reserve capacity to be performe d by the RCCs by the SOR TSOs	1.1.2023	1.9.2023	243
1.2.	Drafting of detailed	Detailed definition of the regional	1.9.2023	28.2.2024	180



	regional process	process of sizing of reserve capacity in cooperati on with the SOR TSOs			
1.3	Clarificati on of IT needs	Definition of the needs for an IT tool in order to fulfil the RCC tasks in cooperati on with the SOR TSOs	1.9.2023	28.2.2024	180
2.	RCC process establish ment		1.9.2023	15.12.202 5	836
2.1.	Internal definition of process	Determini ng the internal RCC process on the regional sizing of reserve capacity	1.9.2023	1.1.2024	122
2.2.	IT specificati on	Specifying the IT tool needed for the internal RCC process of regional sizing of reserve capacity	1.1.2024	15.6.2024	166



2.3.	IT developm ent	Realisatio n of the IT tool needed for the internal RCC process of regional sizing of reserve capacity	15.6.2024	15.6.2025	365
2.4.	IT testing	Testing of the IT tool needed for the internal RCC process of regional sizing of reserve capacity	15.6.2025	15.12.202 5	183
3.	Go-live Phase		1.9.2024	15.6.2026	652
3.1.	Operation al SLA finalisatio n	To finalise the Operation al SLA of the service including the KPIs	1.9.2024	28.2.2025	180
3.2.	Go-live. Check list completio n	Fill and sign the go-live checklist before starting the Parallel run	15.12.202 5	15.3.2026	90
3.3.	Training Operators	Train Operators to provide the service	15.12.202 5	15.3.2026	90



3.4.	Trial Run	Monitor the sizing and procurem ent process of TSOs according to the set process to identify possible risks	15.3.2026	15.6.2026	92
3.5.	Go-live		15.6.2026	15.6.2026	0

451

456

459

460

461

463

465

468

470

472

473

452 FREQUENTLY ASKED QUESTIONS (FAQ)

453	1) Is the proposal aiming for a common methodology for the whole EU Region or for different methodologies
454	for each System Operation Region (SOR)?
455	• The proposal aims for a common pan-FU methodology, but every SOR has dedicated

• The proposal aims for a common pan-EU methodology, but every SOR has dedicated implementation due to the specificities of regions.

457 2) Are different regional IT tools to be developed for the RCC service or a common pan-European tool (similar458 to what we have for STA and OPC)?

- Different tools can be developed for the different SORs.
- But the results of the calculations need to be comparable, so common input/output data contents and formats are to be defined

462 3) Which types of reserves are part of the scope of the proposal (FCR, aFRR, mFRR, RR)?

- aFRR, mFRR and RR
- 464 4) What are the roles and responsibilities of RCCs in the regional procurement of balancing capacity?
 - Please refer to the business process description.

466 5) What are the interdependencies with other services/tools already assessed (e.g. STA, CCC)? Are there 467 any possibilities to use data from other services for this service?

- CCC: available amount of capacity
- 469 STA: ?
 - ROSC: impact of sharing on network flows

471 6) Is the usage of CGMES format to be assessed for the service?

- The CIM format used for the network modelling can be applied for the purposes of this service, too.
- This question is to be decided during the IT development phase, based on actual common requirements.
- 474 475

476 GLOSSARY OF TERMS

The glossary shall provide a short description of the term and a reference where further details can be found(e.g. to regulations, guidelines, descriptions)



Term	Definition			
BSPs (Balancing Service Providers)	EB GL Art 2(6): 'balancing service provider' means a market participant with reserve-providing units or reserve-providing groups able to provide balancing services to TSOs;			
CZCA (Cross Zonal Capacity Allocation)	methodologies for allocating cross-zonal capacity to the balancing timeframe pursuant to Chapter 2 of Title IV of EB GL.			
CZCAOF (Cross Zonal Capacity Allocation Optimisation Function)	Harm. CZCA Method Art. 2(2)(b) 'Cross-zonal capacity allocation optimisation function' means the functionality that determines for each application and for each SPBC in each direction the allocation of cross-zonal capacity for the exchange of energy and for the exchange of balancing capacity or sharing of reserves. For the market timeframes of the co-optimised allocation process and the market-based allocation, the cross-zonal capacity allocation optimisation function shall determine the clearing prices and volumes of balancing capacity of each SPBC per bidding zone;			
DAM (Day-Ahead Market)	CACM Art. 2(34) 'day-ahead market time-frame' means the time-frame of the electricity market until the day-ahead market gate closure time, where, for each market time unit, products are traded the day prior to delivery;			
FCR (Frequency Containment Reserves)	SO GL Art. 3(6) 'frequency containment reserves' or 'FCR' means the active power reserves available to contain system frequency after the occurrence of an imbalance;			
FRCE (Frequency Restoration Control Error)	SO GL Art. 3(43) 'frequency restoration control error' or 'FRCE' means the control error for the frequency restoration process (FRP) which is equal to the area control error (ACE) of a load frequency control (LFC) area or equal to the frequency deviation where the LFC area geographically corresponds to the synchronous area;			
LFCB (Load Frequency Control Block)	SO GL Art. 3(18) 'load-frequency control block' or 'LFC block' means a part of a synchronous area or an entire synchronous area, physically demarcated by points of measurement at interconnectors to other LFC blocks, consisting of one or more LFC areas, operated by one or more TSOs fulfilling the obligations of load-frequency control;			
FRR (Frequency Restoration Reserves), aFRR, mFRR (Automatic/Manual FRR)	SO GL Art. 3(7) 'frequency restoration reserves' or 'FRR' means the active power reserves available to restore system frequency to the nominal frequency and, for a synchronous area consisting of more than one LFC area, to restore power balance to the scheduled value;			
	SO GL Art 3(99) 'automatic FRR' means FRR that can be activated by an automatic control device;			
	Full activation time of standard products of balancing energy			
	aFRR: 5min mFRR: 12.5min			



MCO (Market Coupling Operator)	CACM GL Art. 2(30) 'market coupling operator (MCO) function' means the task of matching orders from the day-ahead and intraday markets for different bidding zones and simultaneously allocating cross-zonal capacities; CACM Whereas (5) The market coupling operator (hereinafter 'MCO') uses a specific algorithm to match bids and offers in an optimal manner. The results of the calculation should be made available to all power exchanges on a non-discriminatory basis. Based on the results of the calculation by the MCO, the power exchanges should inform their clients of the successful bids and offers. The energy should then be transferred across the network according to the results of the MCO's calculation. The process for single day-ahead and intraday coupling is similar, with the exception that the intraday coupling should use a continuous process throughout the day and not one single calculation as in day-ahead coupling.
Regional Sized Reserve Capacity	required reserve capacity for the system operation region
RR (Replacement Reserve)	SO GL Art. 3(8) 'replacement reserves' or 'RR' means the active power reserves available to restore or support the required level of FRR to be prepared for additional system imbalances, including generation reserves; Full activation time of standard products of balancing energy for RR 30 min.
Control Area	SO GL Art. 3(12) 'load-frequency control area' or 'LFC area' means a part of a synchronous area or an entire synchronous area, physically demarcated by points of measurement at interconnectors to other LFC areas, operated by one or more TSOs fulfilling the obligations of load-frequency control;
BSP-TSO gate closure time	EB GL Art. 2(27) 'balancing energy gate closure time' means the point in time when submission or update of a balancing energy bid for a standard product on a common merit order list is no longer permitted;EB GL Art. 24
required local reserve capacity / local reserve capacity needs / NRC	SO GL Art 3(95) 'reserve capacity' means the amount of FCR, FRR or RR that needs to be available to the TSO;
(Needed Reserve Capacity)	In RCC Procurement/Sizing Methodology FCR is out of scope.
available cross-zonal capacity	for CZCA: CZC calculated following CACM GL Art. 14 1(a)
non-contracted balancing energy bids	balancing energy bids, which are submitted without a prior contract for balancing capacity.
	Indirect Definition: EB GL Art 16(5)
balancing energy cooperation platforms, IGCC, PICASSO, MARI, TERRE	EB GL Art. 2(24) 'exchange of balancing energy' means the activation of balancing energy bids for the delivery of balancing energy to a TSO in a different



	scheduling area than the one in which the activated balancing service provider is connected;
	European platforms pursuant to Articles 19(1), 20(1), 21(1) and 22(1) EB GL
	IGCC: International Grid Control Cooperation Imbalance Netting (entsoe.eu)
	PICASSO: Platform for the International Coordination of Automated Frequency Restoration and Stable System Operation <u>PICASSO (entsoe.eu)</u>
	MARI: Manually Activated Reserves Initiative <u>Manually Activated Reserves</u> Initiative (entsoe.eu)
	TERRE: Trans European Replacement Reserves Exchange TERRE (entsoe.eu)
TSO-TSO model	EB GL Art. 2(21) 'TSO-TSO model' means a model for the exchange of balancing services where the balancing service provider provides balancing services to its connecting TSO, which then provides these balancing services to the requesting TSO;
co-optimised allocation of cross-zonal capacity	EB GL Art. 42
market-based allocation	EB GL Art. 41
inverted market-based allocation	EB GL Art. 41 after DA Market + Harm. CZCA Method Art. 2(2)(d)
probabilistic methodology	EB GL Art. 33(6)
forecast of market value	EB GL Art. 39 Calculation of market value of cross-zonal capacity
order books / adjusted order books	collection of all DA orders submitted to the SDAC operator submitted by relevant NEMOs
	adjusted: shifted SDAC order book by CZCA forecast entity
CZC (cross-zonal capacity)	Transmission capacity on bidding zone border
	Regulation (EU) 2019/943 Art. 2 (70) 'Cross-zonal capacity' means as defined in Article 2(70) of Commission Regulation (EU) 2019/943 of the European Parliament and of the Council of 5 June 2019 on the internal market for electricity (recast).
SDAC	CACM Art. 2(26) 'single day-ahead coupling' means the auctioning process where collected orders are matched and cross-zonal capacity is allocated

simultaneously for different bidding zones in the day-ahead market;



CPOF	EB GL Art. 2(42) 'capacity procurement optimisation function' means the function of operating the algorithm applied for the optimisation of the procurement of balancing capacity for TSOs exchanging balancing capacity.
ETP (European Transparency Platform)	Art. 3 of Regulation (EU) No 543/2013
exchange of reserves	SO GL Art. 3(96) 'exchange of reserves' means the possibility of a TSO to access reserve capacity connected to another LFC area, LFC block, or synchronous area to fulfil its reserve requirements resulting from its own reserve dimensioning process of either FCR, FRR or RR and where that reserve capacity is exclusively for that TSO, and is not taken into account by any other TSO to fulfil its reserve requirements resulting from their respective reserve dimensioning processes;
	EB GL Art. 2(23) 'exchange of balancing services' means either or both exchange of balancing energy and exchange of balancing capacity;
	EB GL Art. 2(24) 'exchange of balancing energy' means the activation of balancing energy bids for the delivery of balancing energy to a TSO in a different scheduling area than the one in which the activated balancing service provider is connected;
	EB GL Art. 2(25) 'exchange of balancing capacity' means the provision of balancing capacity to a TSO in a different scheduling area than the one in which the procured balancing service provider is connected;
sharing of reserves	SO GL Art. 3(97) 'sharing of reserves' means a mechanism in which more than one TSO takes the same reserve capacity, being FCR, FRR or RR, into account to fulfil their respective reserve requirements resulting from their reserve dimensioning processes;
SPBC	EB GL Art. 25(2) standard products for balancing capacity for frequency restoration reserves and replacement reserves.
Providing TSO	SO GL Art. 3(103) 'control capability providing TSO' means the TSO that shall trigger the activation of its reserve capacity for a control capability receiving TSO under the conditions of an agreement for sharing reserves;
Receiving TSO	SO GL Art. 3(104) 'control capability receiving TSO' means the TSO calculating reserve capacity by taking into account reserve capacity which is accessible through a control capability providing TSO under the conditions of an agreement for sharing reserves;
Affected TSO	SO GL Art. 3(94): 'affected TSO' means a TSO for which information on the exchange of reserves and/or sharing of reserves and/or imbalance netting process and/or cross-border activation process is needed for the analysis and maintenance of operational security;
ACE open loop	SO GL Art 3(19) 'area control error' or 'ACE' means the sum of the power control error (' Δ P'), that is the real-time difference between the measured actual real time power interchange value ('P') and the control program ('P0') of a



		specific LFC area or LFC block and the frequency control error ('K* Δ f'), that is the product of the K-factor and the frequency deviation of that specific LFC area or LFC block, where the area control error equals Δ P+K* Δ f;
		SAFA B-6-2-2-1-5 ACE open loop (ACEol) means the remaining ACE open loop without contribution of mFRR and RR activations.
positive/negative s incident	izing	SO GL Art. 3(58) 'reference incident' means the maximum positive or negative power deviation occurring instantaneously between generation and demand in a synchronous area, considered in the FCR dimensioning;